

PANDUIT	BRAIDED	INSULATION	NO. OF BRAIDS IN FERRULE	DIMENSIONS - IN [mm]							
PART NUMBER	STRAP SIZE			L	D	S	W	С	т	H DIA	FERRULE LENGTH
BS201246EU	4 AWG	NO	1	12.00 [304.8]	10.75 [273.1]	1.25 [31.8]	1.06 [27.0]	.63 [15.9]	0.13 [3.3]	0.44 [11.2]	2.50 [36.5]
BS201846EU	4 AWG	NO	1	18.00 [457.2]	16.75 [425.5]	1.25 [31.8]	1.06 [27.0]	.63 [15.9]	0.13 [3.3]	0.44 [11.2]	2.50 [36.5]
BS202446EU	4 AWG	NO	1	24.00 [609.6]	22.75 [577.9]	1.25 [31.8]	1.06 [27.0]	.63 [15.9]	0.13 [3.3]	0.44 [11.2]	2.50 [36.5]

REV	DATE	BY	снк	DESCRIPTION	ECN	-R	SUP	C
00	2/08	JHNU	DWDA	DRAWING RELEASED				D
01	10/08	JHNU	DWDA	REVISED NOTE 1: #4 AWG WAS #6, REMOVED NOTE 2				
02	1/09	JHNU	JHNU	REVISED NOTES ADDED FERRULE INFORMATION TO TABLE				
03	1/09	JHNU	JHNU	REMOVED AMPERE RATING FROM TABLE				Γ
04	2/09	JHNU	JHNU	REMOVED CSA SYMBOL FROM DRAWING				1
05	6/11	JHNU	JHNU	REVISED TONGUE MARKINGS: cULus WAS UL	N11002BF-C41745	RGB	RGB	Γ
								1
								Γ

NOTES:

- 1. BRAIDED STRAP IS #4 AWG STRANDED COPPER, TIN PLATED FERRULES ARE TIN PLATED COPPER.
- 2. DIMENSIONS IN PARENTHESIS ARE MILLIMETERS.
- 3. PARTS ARE UL LISTED AND CSA CERTIFIED FOR BONDING APPLICATIONS ONLY.



W	/



